
Enter area, U-factor and temperature difference for each surface.

Surface	Area (sq ft)	U-factor	ΔT (°F)	BTU/h
Walls	1000	0.073	58	4234
Attic	1200	0.026	58	1810
Windows	180	0.3	58	3132
Total				9176

